Community	Sample	DESE Org Code	School Name	School Tap Description	(P)rimary (1st draw) / (F)lushed Sample	DEP Location Type	DEP Location Code	Pb Final	Pb Confirm
	BUTLER								
Belmont	3652761 M2016-0124955 /1	00260015 -	Daniel Butler School -	Classroom 107 -	Primary (1st Draw) -	DW -	010P -	12.7 ug/L	
Belmont	3652761 M2016-0124955 /1	00260015 -	Daniel Butler School -	Classroom 107 -	Flushed -	DW -	010F -	19.6 ug/L	19.2 ug/L
Belmont	3652770 M2016-0124964 /1	00260015 -	Daniel Butler School -	Classroom 109 -	Primary (1st Draw) -	DW -	015P -	26.1 ug/L	24.3 ug/L
Belmont	3652771 M2016-0124965 /1	00260015 -	Daniel Butler School -	Classroom 109 -	Flushed -	DW -	015F -	15.0 ug/L	14.7 ug/L
Belmont	3652776 M2016-0124970 /1	00260015 -	Daniel Butler School -	Classroom 207 -	Primary (1st Draw) -	DW -	018P -	17.3 ug/L	16.5 ug/L
Belmont	3652777 M2016-0124971 /1	00260015 -	Daniel Butler School -	Classroom 207 -	Flushed -	DW -	018F -	34.1 ug/L	35.9 ug/L
Belmont	3652778 M2016-0124972 /1	00260015 -	Daniel Butler School -	Classroom 206 -	Primary (1st Draw) -	DW -	019P -	23.2 ug/L	21.7 ug/L
							019F -	8.78 ug/L	
Belmont	3652786 M2016-0124980 /1	00260015 -	Daniel Butler School -	Classroom 208 -	Primary (1st Draw) -	DW -	023P -	18.8 ug/L	18.8 ug/L
							023F -	3.05 ug/L	
Belmont	3652788 M2016-0124982 /1	00260015 -	Daniel Butler School -	Classroom 209 -	Primary (1st Draw) -	DW -	024P -	26.7 ug/L	27.0 ug/L
							024F -	2.52 ug/L	
	HIGH SCHOOL								
Belmont	3652929 M2016-0125122 /1	00260505 -	Belmont High School -	Boys Locker Room (A) -	Primary (1st Draw) -	DW -	001P -	31.4 ug/L	34 ug/L
					Flushed -		001F	4.94 ug/L	
Belmont	3652931 M2016-0125124 /1	00260505 -	Belmont High School -	Boys Locker Room B -	Primary (1st Draw) -	DW -	002P -	39.8 ug/L	41.9 ug/L
	3652932 M2016-0125125 /1	00260505 -	Belmont High School -	Boys Locker Room B -	Flushed -	DW -	002F -	6.02 ug/L	
Belmont	3652969 M2016-0125160 /1	00260505 -	Belmont High School -	Nurse's Office Cold -	Primary (1st Draw) -	NS -	022P -	25.8 ug/L	25.9 ug/L
					Flushed -			7.01 ug/L	
Belmont	3652977 M2016-0125168 /1	00260505 -	Belmont High School -	Girls locker Room -	Primary (1st Draw) -	DW -	027P -	32.2 ug/L	44.4 ug/L
Belmont	3652978 M2016-0125169 /1	00260505 -	Belmont High School -	Girls locker Room -	Flushed -	DW -	027F -	40.4 ug/L	35.6 ug/L
	BURBANK								

Belmont	3652909 M2016-0125102 /1	00260010 -	Mary Lee Burbank -	Audio Visual -	Primary (1st Draw) -	DW -	023P -	36.4 ug/L	39.8 ug/L
					Flushed -		023F	3.94 ug/L	

Belmont	3652920 M2016-0125113 /1	00260010 -	Mary Lee Burbank -	Classroom 304 -	Primary (1st Draw) -	DW -	030P -	15.4 ug/L	16.1 ug/L
					Flushed -		030F	1.66 ug/L	

CHENERY

Belmont	3652694 M2016-0124888 /1	00260305 -	Winthrop L Chenery Middle School -	classroom 216 -	Primary (1st Draw) -	DW -	009P -	15.9 ug/L	16.3 ug/L
	3652695 M2016-0124889 /1	00260305 -	Winthrop L Chenery Middle School -	classroom 216 -	Flushed -	DW -	009F -	<1.00 ug/L	

WELLINGTON

Belmont	3653008 M2016-0125201 /1	00260035 -	Roger E Wellington School -	Kitchen -	Primary (1st Draw) -	KC -	009P -	40.7 ug/L	40.3 ug/L
	3653009 M2016-0125202 /1	00260035 -	Roger E Wellington School -	Kitchen -	Flushed -	KC -	009F -	3.06 ug/L	